

INTERNATIONAL STANDARD

IEC
60076-10-1

First edition
2005-10

Power transformers –

Part 10-1: Determination of sound levels – Application guide

*This **English-language** version is derived from the original **bilingual** publication by leaving out all French-language pages. Missing page numbers correspond to the French-language pages.*



Reference number
IEC 60076-10-1:2005(E)

INTERNATIONAL STANDARD

IEC
60076-10-1

First edition
2005-10

Power transformers –

Part 10-1: Determination of sound levels – Application guide

© IEC 2005 Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembe, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

X

For price, see current catalogue

CONTENTS

FOREWORD.....	7
1 Scope.....	11
2 Normative references	11
3 Basic physics of sound.....	11
3.1 Sound pressure, p	11
3.2 Particle velocity, u	13
3.3 Sound intensity, I	13
3.4 Sound power, W	13
3.5 Sound fields	15
4 Sources and characteristics of transformer and reactor sound.....	17
4.1 General.....	17
4.2 Sources.....	17
4.3 Vibration transmission.....	27
4.4 Sound radiation.....	29
5 Measuring principles	29
5.1 General.....	29
5.2 Sound pressure level measurement.....	31
5.3 Sound intensity measurements.....	31
5.4 Guidance on narrow-band measurements.....	33
6 Comparison of measuring methods.....	39
6.1 General.....	39
6.2 Sensitivity of the sound pressure method to the test environment.....	41
6.3 Sensitivity of the sound intensity method to test environment.....	43
6.4 Guidance on method selection	47
7 Practical aspects of making sound measurements.....	47
7.1 General.....	47
7.2 Orientation of the test object	47
7.3 Number of measurement points on a measuring surface.....	47
7.4 Choice of microphone spacer for sound intensity measurements.....	49
7.5 Impact of background noise on sound intensity measurements.....	51
7.6 Measurements in the presence of sound-proofing screens	53
8 Difference between factory tests and field sound level measurements.....	53
8.1 General.....	53
8.2 Load power factor	53
8.3 Load current.....	55
8.4 Operating voltage.....	55
8.5 Operating temperature	55
8.6 Harmonics in the load current and voltage.....	57
8.7 DC magnetization.....	57
8.8 Effect of remanent flux	57
8.9 Sound level build-up due to reflections	57
8.10 Influence of distance when making on-site measurements.....	59
8.11 Converter transformers with saturable reactors and/or interphase transformers.....	59

9	Specifying transformer and reactor sound levels.....	61
9.1	General.....	61
9.2	Guarantee sound levels.....	61
9.3	Choice of test method.....	63
9.4	Load conditions.....	65
9.5	Auxiliary cooling equipment.....	67
9.6	Voltage regulation.....	67
9.7	On-site operating conditions.....	67
9.8	Example noise specification for power transformer and cooling auxiliaries (see Annex A).....	67
9.9	Example noise specification for a distribution transformer (see Annex B).....	69
	Annex A (informative) Worked example: Power transformer with cooling auxiliaries mounted on a separate structure >3 m from the principal radiating surface of the transformer – Sound power level determined via sound pressure method.....	71
	Annex B (informative) Worked example: Distribution transformer, sound power determined via time-synchronous sound intensity method.....	91
	Figure 1 – Example curves showing relative change in length for one type of core lamination during complete cycles of applied 50 Hz a.c. induction up to different peak flux densities $B_{max} = 1,2\text{ T} - 1,9\text{ T}$	19
	Figure 2 – Induction (smooth line) and relative change in lamination length (dotted) as a function of time due to applied a.c. induction: 1,8 T, 50 Hz – no d.c. bias.....	21
	Figure 3 – Example curve showing relative change in lamination length during one complete cycle of applied a.c. induction with a small d.c. bias: 1,8 T, 50 Hz and 0,1 T, 0 Hz.....	21
	Figure 4 – Induction (smooth line) and relative change in lamination length (dotted) as a function of time due to applied a.c. induction with a small d.c. bias: 1,8 T, 50 Hz and 0,1 T, 0 Hz.....	23
	Figure 5 – Sound level increase with d.c. current in the windings.....	23
	Figure 6 – Typical load current sound spectrum measured under short-circuit conditions.....	25
	Figure 7 – Microphone arrangement.....	33
	Figure 8 – Test environment.....	41
	Figure 9 – Distribution of disturbances to sound pressure in the test environment.....	43
	Figure 10 – Sketch of dry-type transformer showing measurement points.....	49
	Figure 11 – Illustration of background sound passing through test area and sound radiated from the test object. Microphone pair positions indicated by open (microphone A) and full (microphone B) circles.....	51
	Table 1 – Values of A-weighting as a function of frequency.....	37

INTERNATIONAL ELECTROTECHNICAL COMMISSION

POWER TRANSFORMERS –

**Part 10-1: Determination of sound levels –
Application guide**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60076-10-1 has been prepared by technical committee 14: Power transformers.

This standard is to be read in conjunction with IEC 60076-10.

The text of this standard is based on the following documents:

FDIS	Report on voting
14/505/FDIS	14/513/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 60076 consists of the following parts, under the general title *Power transformers*:

- Part 1: General
- Part 2: Temperature rise
- Part 3: Insulation levels, dielectric tests and external clearances in air
- Part 4: Guide to the lightning impulse and switching impulse testing – Power transformers and reactors
- Part 5: Ability to withstand short circuit
- Part 6: Reactors (under consideration)
- Part 7: Loading guide for oil-immersed power transformers
- Part 8: Application guide
- Part 10: Determination of sound levels
- Part 10-1: Determination of sound levels – Application guide
- Part 11: Dry-type transformers
- Part 12: Loading guide for dry-type power transformers (under consideration)
- Part 13: Self-protected liquid filled transformers
- Part 14: Design and application of liquid-immersed power transformers using high-temperature insulation materials
- Part 15: Gas-filled-type power transformers (under consideration).

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

POWER TRANSFORMERS –

Part 10-1: Determination of sound levels – Application guide

1 Scope

This part of IEC 60076 provides supporting information to help both manufacturers and purchasers apply the measurement techniques described in IEC 60076-10. The sources and characteristics of transformer and reactor sound are described. Practical guidance on making measurements is given, and factors that may influence the accuracy of the methods are discussed. This application guide also clarifies those factors which should be agreed between manufacturer and purchaser when specifying a transformer or reactor, and indicates why values measured in the factory may differ from those measured on site.

This application guide is applicable to transformers and reactors together with their associated cooling auxiliaries.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60076-10:2005, *Power transformers – Part 10: Determination of sound levels*