

INTERNATIONAL STANDARD

IEC
62271-102

First edition
2001-12

High-voltage switchgear and controlgear –
Part 102:
Alternating current disconnectors
and earthing switches

*This **English-language** version is derived from the original **bilingual** publication by leaving out all French-language pages. Missing page numbers correspond to the French-language pages.*



Reference number
IEC 62271-102:2001(E)

INTERNATIONAL STANDARD

IEC 62271-102

First edition
2001-12

High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches

© IEC 2001 Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembe, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE **XD**

For price, see current catalogue

CONTENTS

FOREWORD	13
1 General	21
1.1 Scope	21
1.2 Normative references	21
2 Normal and special service conditions	23
3 Definitions	23
3.1 General terms	23
3.2 Assemblies of switchgear and controlgear	23
3.3 Parts of assemblies	23
3.4 Switching devices	23
3.5 Parts of switching devices	27
3.6 Operation	29
3.7 Characteristic quantities	31
4 Ratings	35
4.1 Rated voltage (U_r)	37
4.2 Rated insulation level	37
4.3 Rated frequency (f_r)	37
4.4 Rated normal current and temperature rise	37
4.5 Rated short-time withstand current (I_k)	37
4.6 Rated peak withstand current (I_p)	39
4.7 Rated duration of short-circuit (t_k)	39
4.8 Rated supply voltage of closing and opening devices and of auxiliary and control circuits (U_a)	39
4.9 Rated supply frequency of closing and opening devices and of auxiliary circuits	39
4.10 Rated pressure of compressed gas supply for insulation and/or operation	39
4.101 Rated short-circuit making current	39
4.102 Rated contact zone	39
4.103 Rated mechanical terminal load	41
4.104 Rated values of the bus-transfer current switching capability of disconnectors	43
4.105 Rated values of the induced current switching capability of earthing switches	45
4.106 Rated values of mechanical endurance for disconnectors and earthing switches	45
4.107 Rated values of electrical endurance for earthing switches	45
5 Design and construction	45
5.1 Requirements for liquids in disconnectors and earthing switches	45
5.2 Requirements for gases in disconnectors and earthing switches	45
5.3 Earthing of disconnectors and earthing switches	45
5.4 Auxiliary and control equipment	47
5.5 Dependent power operation	47
5.6 Stored energy operation	47
5.7 Independent manual operation	47

5.8	Operation of releases.....	47
5.9	Low- and high-pressure interlocking and monitoring devices.....	47
5.10	Nameplates.....	47
5.11	Interlocking devices.....	49
5.12	Position indication.....	49
5.13	Degree of protection by enclosures.....	49
5.14	Creepage distances.....	51
5.15	Gas and vacuum tightness.....	51
5.16	Liquid tightness.....	51
5.17	Flammability.....	51
5.18	Electromagnetic compatibility (EMC).....	51
5.101	Special requirements for earthing switches.....	51
5.102	Requirements in respect of the isolating distance of disconnectors.....	51
5.103	Mechanical strength.....	53
5.104	Operation of disconnectors and earthing switches– Position of the movable contact system and its indicating and signalling devices.....	53
5.105	Maximum force required for manual operation.....	55
5.106	Dimensional tolerances.....	55
6	Type tests.....	57
6.1	General.....	57
6.2	Dielectric tests.....	59
6.3	Radio interference voltage (riv) test.....	63
6.4	Measurement of the resistance of circuits.....	63
6.5	Temperature-rise tests.....	63
6.6	Short-time withstand current and peak withstand current tests.....	63
6.7	Verification of the protection.....	69
6.8	Tightness tests.....	69
6.9	Electromagnetic compatibility tests (EMC).....	69
6.101	Test to prove the short-circuit making performance of earthing switches.....	69
6.102	Operating and mechanical endurance tests.....	71
6.103	Operation under severe ice conditions.....	79
6.104	Operation at the temperature limits.....	83
6.105	Test to verify the proper functioning of the position indicating device.....	85
6.106	Bus-transfer current switching tests.....	85
6.107	Induced current switching tests.....	85
6.108	Bus-charging switching tests.....	85
7	Routine tests.....	85
7.1	Dielectric test on the main circuit.....	85
7.2	Dielectric test on auxiliary and control circuits.....	87
7.3	Measurement of the resistance of the main circuit.....	87
7.4	Tightness test.....	87
7.5	Design and visual checks.....	87
7.101	Mechanical operating tests.....	87

8	Guide to the selection of disconnectors and earthing switches.....	89
8.101	General.....	89
8.102	Selection of rated values for normal service conditions	89
9	Information to be given with enquiries, tenders and orders.....	95
9.101	Information to be given with enquiries and orders	95
9.102	Information to be given with tenders.....	99
10	Rules for transport, storage, installation, operation and maintenance.....	101
10.1	Conditions during transport, storage and installation	101
10.2	Installation	101
10.3	Operation.....	101
10.4	Maintenance	103
11	Safety.....	103
11.1	Electrical aspects.....	103
11.2	Mechanical aspects.....	103
11.3	Thermal aspects	103
11.4	Operation aspects.....	103
Annex A (normative) Design and testing of position indicating devices		117
A.1	General.....	117
A.2	Normal and special service conditions	117
A.3	Definitions.....	117
A.4	Ratings	119
A.5	Design and construction.....	119
A.6	Type tests.....	119
A.7	Routine tests.....	125
Annex B (normative) Bus-transfer current switching by disconnectors		127
B.1	General.....	127
B.2	Normal and special service conditions	127
B.3	Definitions.....	127
B.4	Ratings	129
B.5	Design and construction.....	129
B.6	Type tests.....	131
Annex C (normative) Induced current switching by earthing switches		141
C.1	General.....	141
C.2	Normal and special service conditions	141
C.3	Definitions.....	141
C.4	Ratings	143
C.5	Design and construction.....	145
C.6	Type tests.....	147
Annex D (informative) Test voltage for the most disadvantageous dielectric position of an earthing switch during operation (temporary approach)		161

Annex E (normative) Special requirements for disconnectors and earthing switches used in gas-insulated and/or metal-enclosed switchgear	163
E.1 General.....	163
E.2 Normal and special service conditions	163
E.3 Definitions.....	163
E.4 Ratings	165
E.5 Design and construction.....	165
E.6 Type tests.....	167
E.7 Routine tests.....	169
E.8 Guide to the selection of disconnectors and earthing switches	171
E.9 Information to be given with enquiries, tenders and orders.....	171
E.10 Rules for transport, storage, installation, operation and maintenance.....	171
Annex F (normative) Gas-insulated metal-enclosed switchgear for rated voltages 72,5 kV and above – Requirements for switching of bus-charging currents	173
F.1 General.....	173
F.2 Normal and special service conditions	173
F.3 Definitions.....	173
F.6 Type tests.....	175
Figure 1 – Fixed contact parallel to support.....	103
Figure 2 – Fixed contact (as indicated in figure 8) perpendicular to support	105
Figure 3 – Three-phase test arrangement for disconnectors and earthing switches with rated voltages below 52 kV	105
Figure 4 – Single-phase test arrangement for disconnectors with a horizontal isolating distance and for earthing switches with rated voltage of 52 kV and above	107
Figure 5 – Single-phase test arrangement for divided support disconnectors (earthing switches) with a vertical isolating distance with rated voltages of 52 kV and above to be used with flexible conductors.....	109
Figure 6 – Single-phase test arrangement for divided support disconnectors (earthing switches) with a vertical isolating distance with rated voltages of 52 kV and above to be used with rigid conductors	111
Figure 7 – Example of the application of rated mechanical terminal loads to a two-column disconnector	113
Figure 8 – Example of the application of rated mechanical terminal loads to a pantograph disconnector.....	115
Figure A.1 – Position indicating device.....	125
Figure B.1 – Test circuits for bus-transfer current making and breaking tests	139
Figure C.1 – Test circuit for electromagnetically induced current making and breaking tests.....	157
Figure C.2 – Test circuits for electrostatically induced current making and breaking tests ...	159
Figure F.1 – Test circuit for test duty 1	179
Figure F.2 – Typical voltage waveform (Including VFT and FT components).....	181
Figure F.3 – Test circuit for test duty 2	183
Figure F.4 – Test circuit for test duty 3	183

Table 1 – Recommended contact zones for "fixed" contacts supported by flexible conductors41

Table 2 – Recommended contact zones for "fixed" contacts supported by rigid conductors41

Table 3 – Recommended static mechanical terminal loads43

Table 3a – Classification of disconnectors for mechanical endurance.....45

Table 4 – Nameplate information.....49

Table 5 – Power frequency 1 min withstand voltages61

Table 6 – Power frequency voltage tests87

Table B.1 – Rated bus-transfer voltages for disconnectors 129

Table C.1 – Standardized values of rated induced currents and voltages for earthing switches 145

Table C.2 – Standardized values of recovery voltages for electromagnetically induced current breaking tests 151

Table C.3 – Test circuit capacitances (C_1 values) for electrostatically induced current making and breaking tests..... 153

Table F.1 – Test voltages for making and breaking tests 177

Table F.2 – Specified bus-charging currents 185

Table F.3 – Specified number of tests 185

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –**Part 102: Alternating current disconnectors
and earthing switches**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-102 has been prepared by subcommittee 17A: High-voltage switchgear and controlgear, of IEC technical committee 17: Switchgear and controlgear.

This first edition cancels and replaces the third edition of IEC 60129 published in 1984, amendment 1 (1992) and amendment 2 (1996) and constitutes a technical revision. In addition, it replaces IEC 61128, IEC 61129 and IEC 61259, which are hereby withdrawn and cancelled. A reference table is provided at the end of this foreword.

This bilingual version (2003-08) replaces the English version.

The text of this standard is based on the following documents:

FDIS	Report on voting
17A/617/FDIS	17A/619/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 3.

Annexes A, B, C, E and F form an integral part of this standard.

Annex D is for information only.

This standard should be read in conjunction with IEC 60694, second edition, published in 1996, to which it refers and which is applicable, unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 60694. Additional subclauses are numbered from 101.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

The contents of the corrigenda of April 2002, May 2003 and February 2005 have been included in this copy.

**COMMON NUMBERING OF IEC 62271 PUBLICATIONS FALLING UNDER
THE RESPONSIBILITY OF SUBCOMMITTEES SC 17A AND SC 17C**

In accordance with the decision taken at the joint SC 17A/SC 17C meeting in Frankfurt, June 1998 (item 20.7 of 17A/535/RM), a common numbering system has been established for the publications falling under the responsibility of SC 17A and SC 17C. IEC 62271 – *High-voltage switchgear and controlgear* is the publication number and main title element for the common publications.

The numbering of these publications will apply the following principle.

- a) Common standards prepared by SC 17A and SC 17C will start with IEC 62271-1.
- b) Standards of SC 17A will start with IEC 62271-100.
- c) Standards of SC 17C will start with number IEC 62271-200.
- d) Publications prepared by SC 17A and SC 17C will start with number IEC 62271-300.

The table below relates the new numbers to the old numbers. The parts numbered (xxx) will be given a final number pending the decision to publish the revised publication as standard or technical report.

**Common numbering of IEC 62271 publications falling under the responsibility
of subcommittees SC 17A and SC 17C**

IEC 62271 series	HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –	Old IEC number, if any
Part	New title	
1	Common specifications	IEC 60694
2	Seismic qualification for rated voltages of 72,5 kV and above	-
100	High-voltage alternating current circuit-breakers	IEC 60056
101	Synthetic testing	IEC 60427
102	High-voltage alternating current disconnectors and earthing switches	IEC 60129
103	Switches for rated voltages above 1 kV and less than 52 kV	IEC 60265-1
104	Switches for rated voltages of 52 kV and above	IEC 60265-2
105	Alternating current switch-fuse combinations	IEC 60420
106	Alternating current contactors and contactor-based motor-starters	IEC 60470
107	Alternating current switchgear-fuse combinations	-
108	Switchgear having combined functions	-
109	Series capacitor by-pass switches	-
200	AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV	IEC 60298
201	Insulation-enclosed switchgear and controlgear for rated voltages up to and including 52 kV	IEC 60466
202	High-voltage/low-voltage prefabricated substations	IEC 61330
203	Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV	IEC 60517
204	High-voltage gas-insulated transmission lines for rated voltages of 72,5 kV and above	IEC 61640
(300)	Guide for seismic qualification of high-voltage alternating current circuit-breakers	IEC 61166
(301)	Guide for inductive load switching	IEC 61233
(302)	Guide for short-circuit and switching test procedures for metal-enclosed and dead tank circuit-breakers	IEC 61633
(303)	Use and handling of sulphur hexafluoride (SF ₆) in high-voltage switchgear and controlgear	IEC 61634
(304)	Additional requirements for enclosed switchgear and controlgear from 1 kV to 72,5 kV to be used in severe climatic conditions	IEC 60932
(305)	Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV	IEC 60859
(306)	Direct connection between power transformers and gas-insulated metal-enclosed switchgear for rated voltages above 52 kV	IEC 61639
(307)	Use of electronic and associated technologies in auxiliary equipment of switchgear and controlgear	IEC 62063
308	Guide for asymmetrical short-circuit breaking test duty T100a	-
309	TRV parameters for high-voltage switchgear and controlgear for rated voltages above 1 kV and less than 100 kV	-
310	Electrical endurance testing for circuit-breakers rated 72,5 kV and above	-

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 102: Alternating current disconnectors and earthing switches

1 General

1.1 Scope

This part of IEC 62271 applies to alternating current disconnectors and earthing switches, designed for indoor and outdoor enclosed and open terminal installations for voltages above 1 000 V and for service frequencies up to and including 60 Hz.

It also applies to the operating devices of these disconnectors and earthing switches and their auxiliary equipment.

Additional requirements for disconnectors and earthing switches in enclosed switchgear and controlgear are given in IEC 60298, IEC 60466 and IEC 60517.

NOTE Disconnectors in which the fuse forms an integral part are not covered by this standard.

1.2 Normative references

Subclause 1.2 of IEC 60694 is applicable with the following additions:

IEC 60137:1995, *Insulating bushings for alternating voltages above 1 000 V*

IEC 60265-1:1998, *High-voltage switches – Part 1: Switches for rated voltages above 1 kV and less than 52 kV*

IEC 60265-2:1988, *High-voltage switches – Part 2: High-voltage switches for rated voltages of 52 kV and above*

IEC 60298:1990, *A.C. metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*

IEC 60466:1987, *A.C. insulation-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 38 kV*

IEC 60517:1990, *Gas-insulated metal-enclosed switchgear for rated voltages of 72,5 kV and above*

IEC 60694:1996, *Common specifications for high-voltage switchgear and controlgear standards*

IEC 60865-1:1993, *Short-circuit currents – Calculation of effects – Part 1: Definitions and calculation methods*

ISO 2768-1:1989, *General tolerances – Part 1: Tolerances for linear and angular dimensions without individual tolerance indications*