

INTERNATIONAL STANDARD

IEC 60079-11

Fifth edition
2006-07

Explosive atmospheres –

**Part 11:
Equipment protection by intrinsic safety “i”**

*This **English-language** version is derived from the original **bilingual** publication by leaving out all French-language pages. Missing page numbers correspond to the French-language pages.*



Reference number
IEC 60079-11:2006(E)

INTERNATIONAL STANDARD

IEC 60079-11

Fifth edition
2006-07

Explosive atmospheres –

Part 11: Equipment protection by intrinsic safety “i”

© IEC 2006 Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembe, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE **XE**

For price, see current catalogue

CONTENTS

FOREWORD.....	11
1 Scope.....	15
2 Normative references.....	19
3 Terms and definitions	21
4 Grouping and classification of intrinsically safe apparatus and associated apparatus	31
5 Levels of protection and ignition compliance requirements of electrical apparatus.....	31
5.1 General	31
5.2 Level of protection "ia".....	31
5.3 Level of protection "ib".....	33
5.4 Level of protection "ic".....	33
5.5 Spark ignition compliance	35
5.6 Thermal ignition compliance	35
5.7 Simple apparatus.....	43
6 Apparatus construction	43
6.1 Enclosures	45
6.2 Facilities for connection of external circuits	45
6.3 Separation distances	53
6.4 Protection against polarity reversal	75
6.5 Earth conductors, connections and terminals	75
6.6 Encapsulation.....	79
7 Components on which intrinsic safety depends.....	79
7.1 Rating of components	79
7.2 Connectors for internal connections, plug-in cards and components.....	81
7.3 Fuses	81
7.4 Primary and secondary cells and batteries	83
7.5 Semiconductors.....	91
7.6 Failure of components, connections and separations.....	93
7.7 Piezo-electric devices	95
7.8 Electrochemical cells for the detection of gases	95
8 Infallible components, infallible assemblies of components and infallible connections on which intrinsic safety depends.....	95
8.1 Mains transformers.....	95
8.2 Transformers other than mains transformers.....	99
8.3 Infallible windings	101
8.4 Current-limiting resistors.....	103
8.5 Blocking capacitors.....	103
8.6 Shunt safety assemblies	105
8.7 Wiring, printed circuit board tracks, and connections.....	107
8.8 Galvanically separating components	111

9	Diode safety barriers.....	113
9.1	General	113
9.2	Construction	113
10	Type verifications and type tests	113
10.1	Spark ignition test.....	113
10.2	Temperature tests	123
10.3	Dielectric strength tests	123
10.4	Determination of parameters of loosely specified components.....	125
10.5	Tests for cells and batteries	125
10.6	Mechanical tests.....	129
10.7	Tests for apparatus containing piezoelectric devices	129
10.8	Type tests for diode safety barriers and safety shunts	131
10.9	Cable pull test	133
10.10	Transformer tests	133
11	Routine verifications and tests	133
11.1	Routine tests for diode safety barriers	133
11.2	Routine tests for infallible transformers	135
12	Marking	135
12.1	General	135
12.2	Marking of connection facilities	137
12.3	Warning markings	137
12.4	Examples of marking	139
13	Documentation	141
	Annex A (normative) Assessment of intrinsically safe circuits.....	143
	Annex B (normative) Spark test apparatus for intrinsically safe circuits	187
	Annex C (informative) Measurement of creepage distances, clearances and separation distances through casting compound and through solid insulation.....	205
	Annex D (informative) Encapsulation	211
	Annex E (informative) Transient energy test	219
	Annex F (normative) Alternative separation distances for assembled printed circuit boards and separation of components	225
	Bibliography.....	233
	Figure 1 – Separation of intrinsically safe and non-intrinsically safe terminals	51
	Figure 2 – Example of separation of conducting parts.....	59
	Figure 3 – Determination of creepage distances	67
	Figure 4 – Creepage distances and clearances on printed circuit boards.....	69
	Figure 5– Examples of independent and non-independent connecting elements.....	77
	Figure 6 – Infallible solder connection of surface mount component in accordance with 8.7 c) 3).....	109
	Figure A.1 – Resistive circuits	149
	Figure A.2 – Group I capacitive circuits	151
	Figure A.3 – Group II capacitive circuits	153
	Figure A.4 – Inductive circuits of Group II	155

Figure A.5 – Group I inductive circuits	157
Figure A.6 – Group IIC inductive circuits.....	159
Figure A.7 – Simple inductive circuit.....	161
Figure A.8 – Simple capacitive circuit	161
Figure A.9 – Equivalent capacitance.....	185
Figure B.1 – Spark test apparatus for intrinsically safe circuits.....	193
Figure B.2 – Cadmium contact disc	195
Figure B.3 – Wire holder	195
Figure B.4 – Example of a practical design of spark test apparatus.....	197
Figure B.5 – Example of an explosion pressure switch.....	199
Figure B.6 – Example of automatic stopping by means of an explosion pressure switch	201
Figure B.7 – Arrangement for fusing tungsten wires.....	203
Figure B.8 – Circuit diagram for fusing tungsten wires	203
Figure C.1 – Measurement of clearance	205
Figure C.2 – Measurement of composite distances	205
Figure C.3 – Measurement of creepage.....	207
Figure C.4 – Measurement of composite creepage	209
Figure D.1 – Examples of encapsulated assemblies conforming to 6.3.4 and 6.6	213
Figure D.2 – Applications of encapsulation without enclosure.....	217
Figure E1 – Example of test circuit	223
Figure E2 – Example of output waveform.....	223
Table 1 – Exclusion of specific clauses of IEC 60079-0	15
Table 2 – Assessment of temperature classification according to component size and ambient temperature	37
Table 3 – Temperature classification of copper wiring (in a maximum ambient temperature of 40 °C).....	39
Table 4 – Temperature classification of tracks on printed circuit boards (in a maximum ambient temperature of 40 °C)	41
Table 5 – Clearances, creepage distances and separations	57
Table 6 – Minimum foil thickness or minimum wire diameter of the screen in relation to the rated current of the fuse	97
Table 7 – Compositions of explosive test mixtures adequate for 1,0 safety factor.....	117
Table 8 – Compositions of explosive test mixtures adequate for 1,5 safety factor.....	117
Table 9 – Routine test voltages for infallible transformers	135
Table 10 – Text of warning markings	137
Table A.1 – Permitted short-circuit current corresponding to the voltage and the apparatus group.....	163
Table A.2 – Permitted capacitance corresponding to the voltage and the apparatus group	173
Table A.3 – Permitted reduction of effective capacitance when protected by a series resistance	185

Table F.1 – Clearances, creepage distances and separations for level of protection "ia" and "ib" when ingress protected, and special conditions of material and installation are fulfilled 229

Table F.2 – Clearances, creepage distances and separations for level of protection "ic" when ingress is protected by an enclosure or by special conditions of installation 231

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –**Part 11: Equipment protection by intrinsic safety "i"**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-11 has been prepared by subcommittee 31G: Intrinsically safe apparatus, of IEC technical committee 31: Equipment for explosive atmospheres.

This fifth edition cancels and replaces the fourth edition published in 1999 and constitutes a full technical revision.

The significant changes with respect to the previous edition are listed below:

- introduction of level of protection "ic" (this level of protection has been introduced to allow removal of the 'energy limitation' concept from 60079-15);
- introduction of Annex F that allows reduction in segregation distance requirements when the pollution degree has been reduced by installation or enclosure;
- introduction of alternative spark test apparatus construction when used with high current circuits;
- introduction of Annex E that provides a method for transient energy test;

- changes in the table of 'Temperature classification of tracks on PCB's' to allow correlation with IPC-2152;
- allowing alternative methods of rating resistors when used to limit the discharge from capacitance;
- introduction of methods to deal with the spark ignition energy consideration when high current low voltage cells and batteries are used;
- introduction of tests to measure the maximum pressure in sealed battery containers;
- introduction of methods to deal with fault application on voltage enhancement IC's;
- introduction of infallible connection methods for SMD's (surface mount devices);
- introduction of alternative methods to deal with the spark ignition energy in circuits with both inductance and capacitance;
- introduction of alternative high voltage test for transformers;
- introduction of methods to assess the reduction of effective capacitance when protected by series resistances;
- introduction of Group I data for permitted short circuit current and permitted capacitance in the tables of Annex A.

The text of this standard is based on the following documents:

FDIS	Report on voting
31G/159/FDIS	31G/161/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This standard supplements and modifies the general requirements of IEC 60079-0, except as indicated in Table 1 (see Scope).

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60079 series, under the general title: *Explosives atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under <http://webstore.iec.ch> in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

EXPLOSIVE ATMOSPHERES –

Part 11: Equipment protection by intrinsic safety "i"

1 Scope

This part of IEC 60079 specifies the construction and testing of intrinsically safe apparatus intended for use in an explosive gas atmosphere and for associated apparatus, which is intended for connection to intrinsically safe circuits which enter such atmospheres.

This type of protection is applicable to electrical apparatus in which the electrical circuits themselves are incapable of causing an explosion in the surrounding explosive atmospheres.

This standard is also applicable to electrical apparatus or parts of electrical apparatus located outside the explosive gas atmosphere or protected by another type of protection listed in IEC 60079-0, where the intrinsic safety of the electrical circuits in the explosive gas atmosphere may depend upon the design and construction of such electrical apparatus or parts of such electrical apparatus. The electrical circuits exposed to the explosive gas atmosphere are evaluated for use in such an atmosphere by applying this standard.

The requirements for intrinsically safe systems are provided in IEC 60079-25. The requirements for intrinsically safe concepts for fieldbus are provided in IEC 60079-27.

This standard supplements and modifies the general requirements of IEC 60079-0, except as indicated in Table 1. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirements of this standard shall take precedence.

If associated apparatus is placed in the explosive gas atmosphere, it must be protected by an appropriate type of protection listed in IEC 60079-0, and then the requirements of that method of protection together with the relevant parts of IEC 60079-0 also apply to the associated apparatus.

Table 1 – Exclusion of specific clauses of IEC 60079-0

Clause or subclause of IEC 60079-0		Intrinsically safe apparatus	Associated apparatus
4.2.2	Group II – Surface temperature marking	Applies	Excluded
5.3	Maximum surface temperature	Applies	Excluded
5.4	Surface temperature and ignition temperature	Applies	Excluded
5.5	Small components	Applies	Excluded
6.3	Opening times	Excluded	Excluded
7.1.1	Applicability	Applies	Excluded
7.1.2	Specification of materials	Applies	Excluded
7.1.3*	Plastic materials	Excluded	Excluded
7.2*	Thermal endurance	Excluded	Excluded
7.3	Electrostatic charges on external non-metallic materials of enclosures	Applies	Excluded
7.3.2	Avoidance of a build-up electrostatic charge	Applies	Excluded
7.4	Threaded holes	Excluded	Excluded

Table 1 (continued)

Clause or subclause of IEC 60079-0		Intrinsically safe apparatus	Associated apparatus
8.1	Material composition	Applies	Excluded
8.2	Threaded holes	Excluded	Excluded
9	Fasteners	Excluded	Excluded
10	Interlocking devices	Excluded	Excluded
11	Bushings	Excluded	Excluded
12	Materials used for cementing	Excluded	Excluded
14	Connection facilities and terminal compartments	Excluded	Excluded
15	Connection facilities for earthing or bonding conductors	Excluded	Excluded
16.5	Conductor temperature	Excluded	Excluded
17	Supplementary requirements for rotating electrical machines	Excluded	Excluded
18	Supplementary requirements for switchgear	Excluded	Excluded
19	Supplementary requirements for fuses	Excluded	Excluded
20	Supplementary requirements for plugs and sockets	Excluded	Excluded
21	Supplementary requirements for luminaires	Excluded	Excluded
22	Supplementary requirements for caplights and handlights	Excluded	Excluded
23.1	Batteries	Applies	Excluded
26.4	Tests of enclosures	Applies	Excluded
26.5.1	Temperature measurement	Applies	Excluded
26.5.2	Thermal shock test	Excluded	Excluded
26.5.3	Small component ignition test	Applies	Excluded
26.6	Torque test for bushings	Excluded	Excluded
26.7*	Non-metallic enclosures or non-metallic parts of enclosures	Excluded	Excluded
26.8*	Thermal endurance to heat	Excluded	Excluded
26.9*	Thermal endurance to cold	Excluded	Excluded
26.10*	Resistance to light	Excluded	Excluded
26.11*	Resistance to chemical agents for Group I electrical apparatus	Excluded	Excluded
26.12	Earth continuity	Excluded	Excluded
26.13	Surface resistance test of parts of enclosures or non-metallic materials	Applies	Excluded
26.14	Charging tests	Applies	Excluded
26.15	Measurement of capacitance	Applies	Excluded
Annex A	Ex cable glands	Excluded	Excluded

* indicates that these requirements apply for 6.1.2a) only.

2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of IEC 60079. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0:2004, *Electrical apparatus for explosive gas atmospheres – Part 0: General requirements*

IEC 60079-7, *Explosive atmospheres – Part 7: Equipment protection by increased safety "e"*

IEC 60079-25, *Electrical apparatus for explosive gas atmospheres – Part 25: Intrinsically safe systems*

IEC 60079-27, *Electrical apparatus for explosive gas atmospheres – Part 27: Fieldbus intrinsically safe concept (FISCO) and Fieldbus non-incendive concept (FNICO)*

IEC 60085, *Electrical insulation – Thermal classification*

IEC 60112, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60127 (all parts), *Miniature fuses*

IEC 60317-3, *Specifications for particular types of winding wires – Part 3: Polyester enamelled round copper wire, class 155*

IEC 60317-7, *Specifications for particular types of winding wires – Part 7: Polyimide enamelled round copper wire, class 220*

IEC 60317-8, *Specifications for particular types of winding wires – Part 8: Polyesterimide enamelled round copper winding wire, class 180*

IEC 60317-13, *Specifications for particular types of winding wires – Part 13: Polyester or polyesterimide overcoated with polyamide-imide enamelled round copper wire, class 200*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60664-1:2002, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests* ¹⁾

Amendment 1 (2000)

Amendment 2 (2002)

¹⁾ A consolidated edition 1.2 exists, that comprises IEC 60664-1 and its amendments 1 and 2.

IEC 60664-3:2003, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

ANSI/UL 248-1, *Low-Voltage Fuses – Part 1: General Requirements*